

FIRE SAFETY CERTIFICATE

No: FA/AVK/JUNE/01

Date- 17/06/2025

Certificate that the RBK School Building at Ghatkopar Mankhurd Link Road, C.T.S. No.2/7 of Village Borla, Chembur, Mumbai comprised of Basement + Ground + 1st to 4 floors occupied by RBK School have complied with the fire prevention and safety requirements in accordance with the rules as per Maharashtra Fire Prevention & Life Safety Measures Act 2006 and were verified by the undersigned on 6/06/2025, in presence of the Manager of the school Mr. Prasad Pradeshi and that the School Building (Basement for services and Ground + 1st to 4th upper floors) is fit for occupation up to classes X with effect from 6/06/2025 for a period of one year in accordance with the rule and subject to compliance of specific condition as appended.

1. The entire firefighting and fire safety system provided in the building such as Fire Hydrant System, Fire Pumps, Automatic Sprinkler system, Fire Alarm and Smoke /Heat Detection system, Public Address system, Fire Extinguishers, Exit signage shall be maintained in good working condition all the time.
2. A certificate (From B) regarding good working condition of all the above fire systems is provided issued by M/s Verizon Safety Services u/n VS/2024-25/06 dated 02/01/2025 having Lic No MFS/LA/RF-93/RD-98. It shall be submitted fresh to local fire authority in the month of January 2026 from Gov. approved Licensed Agency.
3. Both the staircases of the Building shall be kept open/operational all the time for evacuation in case of any emergency from 4th floor to ground floor.
4. Security guards having basic knowledge of firefighting and evacuation shall be available during entire school working hours.

To,
The Principal,
RBK SCHOOL
Ghatkopar - Mankhurd Link Road,
ACC Nagar, Chedda Nagar,
Mumbai , Maharashtra .

Name: Abhay V. K
Designation : Fire Officer
(Authenticated by Directorate of
Maharashtra Fire Service)
Add: 701/702, Om Shiv CHS,
Mogul Lane, Mahim (West),
Mumbai - 400016
Mobile : 9930464827
E-Mail: abhayfire@gmail.com



ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....(reasons to be recorded)

(Name and designation of the authorized Signatory)


**PRINCIPAL
RBK SCHOOL**


**MANAGER
RBK SCHOOL**